

### NA90

#### FEEDER PROTECTION RELAY

THE COMPREHENSIVE SOLUTION FOR TRANSFORMERS PROTECTION.


DIRECTIONAL OVERCURRENT, STAND-BY AND RESIDUAL/REF IN ONE-RELAY SOLUTION



#### — Application

The relay type NA90 can be typically used in radial or meshed MV and LV networks as feeder or power transformer protection:

- On radial, ring and parallel feeders of any length in solidly grounded, ungrounded, Petersen coil and/or resistance grounded systems.
  - On parallel connected generators and transformer on the same busbar.
  - For ground fault protection on both sides of power MV-LV transformers.
- Moreover undervoltage and overvoltage are provided.



#### - Protective & control functions

27	Undervoltage
49	Thermal image (for lines and transformers)
50/51	Phase overcurrent
50N(1)/51N(1)	Measured residual overcurrent
50N(2)/51N(2)	Measured residual overcurrent
50N(Comp)/51N(Comp)	Computed residual overcurrent
59	Overvoltage
59N	Residual overvoltage
67	Directional phase overcurrent
67N	Directional earth fault overcurrent
BF	Circuit breaker failure
74CT	CTs monitoring
74TCS	Trip circuit supervision

### — Firmware updating

The use of flash memory units allows on-site firmware updating.

### — Measuring inputs

- Three phase current inputs and one residual current input ( $I_{E1}$ ), with nominal currents independently selectable at 1 A or 5 A through DIP-switches.
- One residual current input ( $I_{E2}$ ), with nominal current at 1 A.
- Three phase voltage inputs with programmable nominal voltages within range 50...130 V ( $U_R = 100$  V) or 200...520 V ( $U_R = 400$  V).

### — Construction

According to the hardware configurations, the NA90 protection relay can be shipped in various case styles depending on the required mounting options (flush, projecting mounting, rack or with separate operator panel).

### — Modular design

In order to extend I/O capability, the NA90 hardware can be customized through external auxiliary modules:

- MRI - Output relays and LEDs
- MID16 - Binary inputs
- MCI - 4...20 mA converters
- MPT - Pt100 thermal probes.



### — Binary inputs

Two binary inputs are available with programmable active state (active-ON/active-OFF) and programmable timer (active to OFF/ON or ON/OFF transitions). Several presettable functions can be associated to each input.

### — Two set point profiles (A,B)

Two independent groups of settings are provided. Switching from profiles may be operated by means of MMI, binary input and communication.

### — Blocking input/outputs

One output blocking circuit and one input blocking circuit are provided.

The output blocking circuits of one or several Pro\_N relays, shunted together, must be connected to the input blocking circuit of the protection relay, which is installed upstream in the electric plant. The output circuit works as a simple contact, whose condition is detected by the input circuit of the upstream protection relay.

Use of suitable pilot wire to fiber optic converters (BFO) allows to perform fast and reliable accelerated logic selectivity on radial and closed ring networks.

### — Output relays


Six output relays are available (two changeover, three make and one break contacts); each relay may be individually programmed as normal state (normally energized, de-energized or pulse) and reset mode (manual or automatic).

A programmable timer is provided for each relay (minimum pulse width). The user may program the function of each relay according to a matrix (tripping matrix) structure.

### — MMI (Man Machine Interface)

The user interface comprises a membrane keyboard, a backlight LCD alphanumeric display and eight LEDs.

The green ON LED indicates auxiliary power supply and self diagnostics, two LEDs are dedicated to the Start and Trip (yellow for Start, red for Trip) and five red LEDs are user assignable.



### — Communication

Multiple communication interfaces are implemented:

- One RS232 local communication front-end interface for communication with ThySetter setup software.
- Two back-end interfaces for communication with remote monitoring and control systems by:
  - RS485 port using ModBus® RTU, IEC 60870-5-103 or DNP3 protocol.
  - Ethernet port (RJ45 or optical fiber) using ModBus/TCP protocol.

### — Programming and settings


All relay programming and adjustment operations may be performed through MMI (Keyboard and display) or using a Personal Computer with the aid of the ThySetter software.

The same PC setup software is required to set, monitor and configure all Pro\_N devices.

Full access to the available data is provided:

- Read status and measures.
- Read/edit settings (on-line or off-line edit).

Two session level (User or Administrator) with password for sensible data access are provided.



## — Control and monitoring

Several predefined functions are implemented:

- Activation of two set point profiles.
- Phase CTs and VTs monitoring (74CT and 74VT).
- Logic selectivity.
- Cold load pickup (CLP) with block or setting change.
- Trip circuit supervision (74TCS).
- Second harmonic restraint (inrush).
- Remote tripping.
- Circuit Breaker commands and diagnostic.
- Programmable logic (PLC).

### **Circuit Breaker**

Several diagnostic, monitoring and control functions are provided:

- Health thresholds can be set; when the accumulated duty ( $\Sigma I$  or  $\Sigma I^2t$ ), the number of operations or the opening time exceeds the threshold an alarm is activated.
- Breaker failure (BF); breaker status is monitored by means 52a-52b and/or through line current measurements.
- Trip circuit supervision (74TCS).
- Breaker control; opening and closing commands can be carried out locally or remotely.

### **Cold Load Pickup (CLP)**

Cold load pickup element prevents unwanted tripping in case of temporary overcurrents produced when a feeder is being connected after an extended outage (e.g. motor starting).

Two different operating modes are provided:

- Each protective element may be blocked for a programmable time.
- Each threshold can be increased for a programmable time.

### **Second harmonic restraint**

To prevent unwanted tripping of the protective functions on transformer inrush current, the protective elements can be blocked when the ratio between the second harmonic current and the relative fundamental current is larger than a user programmable threshold.

The function can be programmed to switch an output relay so as to cause a blocking protection relays lacking in second harmonic restraint.

### **Logic selectivity**

With the aim of providing a fast selective protection system some protective functions may be blocked (pilot wire accelerated logic). To guarantee maximum fail-safety, the relay performs a run time monitoring for pilot wire continuity and pilot wire shorting. Exactly the output blocking circuit periodically produces a pulse, having a small enough width in order to be ignored as an effective blocking signal by the input blocking circuit of the upstream protection, but suitable to prove the continuity of the pilot wire.

Furthermore a permanent activation (or better, with a duration longer than a preset time) of the blocking signal is identified, as a warning for a possible short circuit in the pilot wire or in the output circuit of the downstream protection.

### **Programmable logic**

User defined logic may be customized according to IEC 61131-3 standard protocol (PLC).<sup>[1]</sup>

*Note 1 - A licence is required; call Thytronic for purchasing.*

## — Self diagnostics

All hardware and software functions are repeatedly checked and any anomalies reported via display messages, communication interfaces, LEDs and output relays.

Anomalies may refer to:

- Hw faults (auxiliary power supply, output relay coil interruptions, MMI board...).
- Sw faults (boot and run time tests for data base, EEPROM memory checksum failure, data BUS,...).
- Pilot wire faults (break or short in the wire).
- Circuit breaker faults.

## — Metering

NA90 provides metering values for phase and residual currents, phase and residual voltage, making them available for reading on a display or to communication interfaces.

Input signals are sampled 24 times per period and the RMS value of the fundamental component is measured using the DFT (Discrete Fourier Transform) algorithm and digital filtering.

With DFT the RMS value of 2nd, 3rd, 4th and 5th harmonic of phase current are also measured.

On the base of the direct measurements, several calculated (min, max, average,...), phase, sequence, power, harmonic, demand and energy measures are processed.

Measures can be displayed with reference to nominal values or directly expressed in amperes and volts.

## — Event storage

Several useful data are stored for diagnostic purpose; the events are stored into a non volatile memory.

They are graded from the newest to the older after the "Events reading" command (ThySetter) is issued:

- Sequence of Event Recorder (SER).

The event recorder runs continuously capturing in circular mode the last three hundred events upon trigger of binary input/output.

- Sequence of Fault Recorder (SFR).

The fault recorder runs continuously capturing in circular mode the last twenty faults upon trigger of binary input/output and/or element pickup (start-trip).

- Trip counters.


## — Digital Fault Recorder (Oscillography)

Upon trigger of tripping/starting of each function or external signals, the relay records in COMTRADE format:

- Oscillography with instantaneous values for transient analysis.
- RMS values for long time periods analysis.
- Logic states (binary inputs and output relays).

*Note - A license for Digital Fault Recorder function is required, for purchase procedure please contact Thytronic.*

*The records are stored in nonvolatile memory*



# SPECIFICATIONS

## GENERAL

- **Mechanical data**  
Mounting: flush, projecting, rack or separated operator panel  
Mass (flush mounting case) 2.0 kg
- **Insulation tests**  
Reference standards EN 60255-5  
High voltage test 50Hz 2 kV 60 s  
Impulse voltage withstand (1.2/50  $\mu$ s) 5 kV  
Insulation resistance >100 M $\Omega$
- **Voltage dip and interruption**  
Reference standards EN 61000-4-29
- **EMC tests for interference immunity**  
1 MHz damped oscillatory wave EN 60255-22-1 1 kV-2.5 kV  
Electrostatic discharge EN 60255-22-2 8 kV  
Fast transient burst (5/50 ns) EN 60255-22-4 4 kV  
Conducted radio-frequency fields EN 60255-22-6 10 V  
Radiated radio-frequency fields EN 60255-4-3 10 V/m  
High energy pulse EN 61000-4-5 2 kV  
Magnetic field 50 Hz EN 61000-4-8 1 kA/m  
Damped oscillatory wave EN 61000-4-12 2.5 kV  
Ring wave EN 61000-4-12 2 kV  
Conducted common mode (0...150 kHz) EN 61000-4-16 10 V
- **Emission**  
Reference standards EN 61000-6-4 (ex EN 50081-2)  
Conducted emission 0.15...30 MHz Class A  
Radiated emission 30...1000 MHz Class A
- **Climatic tests**  
Reference standards IEC 60068-x, ENEL R CLI 01, CEI 50
- **Mechanical tests**  
Reference standards EN 60255-21-1, 21-2, 21-3
- **Safety requirements**  
Reference standards EN 61010-1  
Pollution degree 3  
Reference voltage 250 V  
Overvoltage III  
Pulse voltage 5 kV  
Reference standards EN 60529  
Protection degree:  
• Front side IP52  
• Rear side, connection terminals IP20
- **Environmental conditions**  
Ambient temperature -25...+70 °C  
Storage temperature -40...+85 °C  
Relative humidity 10...95 %  
Atmospheric pressure 70...110 kPa
- **Certifications**  
Product standard for measuring relays EN 50263  
CE conformity  
• EMC Directive 89/336/EEC  
• Low Voltage Directive 73/23/EEC  
Type tests IEC 60255-6

## COMMUNICATION INTERFACES

- Local PC RS232 19200 bps
- Network:  
• RS485 1200...57600 bps  
• Ethernet 100BaseT 100 Mbps  
Protocol ModBus® RTU/IEC 60870-5-103/DNP3, TCP/IP

## INPUT CIRCUITS

- **Auxiliary power supply Uaux**  
Nominal value (range) 24...48 Vac/dc, 115...230 Vac/110...220 Vdc  
Operative range (each one of the above nominal values) 19...60 Vac/dc  
85...265 Vac/75...300 Vdc  
  
*Power consumption:*  
• Maximum (energized relays, Ethernet TX) 10 W (20 VA)  
• Maximum (energized relays, Ethernet FX) 15 W (25 VA)
- **Phase current inputs**  
Nominal current  $I_n$  1 A or 5 A selectable by DIP Switches  
Permanent overload 25 A  
Thermal overload (1s) 500 A  
Rated consumption (for any phase)  $\leq 0.002$  VA ( $I_n = 1$  A)  
 $\leq 0.04$  VA ( $I_n = 5$  A)
- **Residual current input  $I_{E1}$**   
Nominal current  $I_{En}$  1 A or 5 A selectable by DIP Switch  
Permanent overload 25 A  
Thermal overload (1s) 500 A  
Rated consumption  $\leq 0.006$  VA ( $I_{En} = 1$  A)  
 $\leq 0.012$  VA ( $I_{En} = 5$  A)
- **Residual current input  $I_{E2}$**   
Nominal current  $I_{En}$  1 A  
Permanent overload 5 A  
Thermal overload (1s) 100 A  
Rated consumption  $\leq 0.006$  VA
- **Voltage inputs**  
Reference voltage  $U_R$  100 V or 400 V selectable on order  
Nominal voltage  $U_n$  50...130 V or 200...520 V adjustable via sw  
Permanent overload 1.3  $U_R$   
1s overload 2  $U_R$   
Rated consumption (for any phase)  $\leq 0.5$  VA
- **Binary inputs**  
Quantity 2  
Type dry inputs  
Max permissible voltage 19...265 Vac/19...300 Vdc  
Max consumption, energized 3 mA
- **Block input (Logic selectivity)**  
Quantity 1  
Type polarized wet input (powered by internal isolated supply)  
Max consumption, energized 5 mA

## OUTPUT CIRCUITS

- **Output relays K1...K6**  
Quantity 6  
• Type of contacts K1, K2 changeover (SPDT, type C)  
• Type of contacts K3, K4, K5 make (SPST-NO, type A)  
• Type of contacts K6 break (SPST-NC, type B)  
Nominal current 8 A  
Nominal voltage/max switching voltage 250 Vac/400 Vac  
*Breaking capacity:*  
• Direct current (L/R = 40 ms) 50 W  
• Alternating current ( $\lambda = 0.4$ ) 1250 VA  
Make 1000 W/VA  
Short duration current (0,5 s) 30 A
- **Block output (Logic selectivity)**  
Quantity 1  
Type optocoupler
- **LEDs**  
Quantity 8  
• ON/fail (green) 1  
• Start (yellow) 1  
• Trip (red) 1  
• Allocatable (red) 5



## GENERAL SETTINGS

### Rated values

Relay nominal frequency ( $f_n$ )	50, 60 Hz
Relay phase nominal current ( $I_n$ )	1 A, 5 A
Phase CT nominal primary current ( $I_{np}$ )	1 A...10 kA
Relay residual nominal current ( $I_{E1n}$ )	1 A, 5 A
Relay residual nominal current ( $I_{E2n}$ )	1 A
Residual CT nominal primary current ( $I_{E1np}$ )	1 A...10 kA
Residual CT nominal primary current ( $I_{E2np}$ )	1 A...10 kA
Relay nominal voltage (phase-to-phase) ( $U_n$ )	50...130 V or 200...520 V
Relay nominal voltage (phase-to-ground)	$E_n = U_n/\sqrt{3}$
Line VT primary nominal voltage (phase-to-phase) ( $U_{np}$ )	50 V...500 kV
Relay residual nominal voltage (computed measure) ( $U_{ECn}$ )	$U_{ECn} = \sqrt{3} \cdot U_n = 3 \cdot E_n$
Relay nominal active power ( $P_n$ )	$P_n = \sqrt{3} \cdot U_n \cdot I_n = 3 \cdot E_n \cdot I_n$
Relay nominal reactive power ( $Q_n$ )	$Q_n = \sqrt{3} \cdot U_n \cdot I_n = 3 \cdot E_n \cdot I_n$
Relay nominal apparent power ( $S_n$ )	$S_n = \sqrt{3} \cdot U_n \cdot I_n = 3 \cdot E_n \cdot I_n$

### Binary input timers

ON delay time (IN1 $t_{ON}$ , IN2 $t_{ON}$ ,...IN5 $t_{ON}$ )	0.00...100.0 s
OFF delay time (IN1 $t_{OFF}$ , IN2 $t_{OFF}$ ,...IN5 $t_{OFF}$ )	0.00...100.0 s
Logic	Active-ON/Active-OFF

### Relay output timers

Minimum pulse width ( $t_{TR}$ )	0.000...0.500 s
----------------------------------	-----------------

## PROTECTIVE FUNCTIONS

### Base current $I_B$ <sup>[1]</sup>

Base current ( $I_B$ )	0.10...2.50 $I_n$
------------------------	-------------------

Note 1: The basic current  $I_B$  represents the nominal current of the line or transformer, referred to the nominal current of the CT's for thermal image protection. If the secondary rated current of the line CT's equals the rated current of the relay, as usually happens, the  $I_B$  value is the ratio between the rated current of the protected element and the primary rated current of the CT's

### Thermal protection with RTD thermometric probes - 26

Alarm	
• Alarm threshold $\theta_{ALx}$ ( $x=1...8$ )	0...200 °C
• Operating time $t_{\theta ALx}$ ( $x=1...8$ )	0...100 s
Trip	
• Trip threshold $\theta_{Tx}$ ( $x=1...8$ )	0...200 °C
• Operating time $t_{\theta Tx}$ ( $x=1...8$ )	0...100 s

Note: The element becomes available when the MPT module is enabled and connected to Thybus

### Undervoltage - 27

Common configuration:

- Voltage measurement type for 27 ( $U_{type27}$ ) <sup>[1]</sup>  $U_{ph-ph}/U_{ph-n}$
- 27 Operating logic (Logic27) AND/OR

$U < Element$

- $U < Curve$  type ( $U < Curve$ ) DEFINITE INVERSE <sup>[2]</sup>

Definite time

- 27 First threshold definite time ( $U <_{def}$ ) 0.05...1.10  $U_n/E_n$
- $U <_{def}$  Operating time ( $t_{U <_{def}}$ ) 0.03...100.0 s

Inverse time

- 27 First threshold inverse time ( $U <_{inv}$ ) 0.05...1.10  $U_n/E_n$
- $U <_{inv}$  Operating time ( $t_{U <_{inv}}$ ) 0.10...100.0 s

$U < < Element$

Definite time

- 27 Second threshold definite time ( $U < <_{def}$ ) 0.05...1.10  $U_n/E_n$
- $U < <_{def}$  Operating time ( $t_{U < <_{def}}$ ) 0.03...100.0 s

Note 1: With  $U_{ph-ph}$  setting all threshold are in p.u.  $U_n$  with  $U_{ph-n}$  setting all threshold are in p.u.  $E_n$

Note 2: The mathematical formula for INVERSE curves is:  
 $t = 0.75 \cdot t_{U <_{inv}} / [1 - (U/U <_{inv})]$

where:

$t$  = operating time (in seconds)

$t_{U <_{inv}}$  = operating time setting (in seconds)

$U$  = input voltage

$U <_{inv}$  = threshold setting

### Thermal image - 49

Common configuration:

- Initial thermal image  $\Delta\theta_{IN}$  ( $Dth_{IN}$ ) 0.0...1.0  $\Delta\theta_B$
- Reduction factor at inrush ( $K_{INR}$ ) 1.0...3.0
- Thermal time constant  $\tau$  ( $T$ ) 1...200 min
- $Dth_{CLP}$  Activation time ( $t_{DthCLP}$ ) 0.00...100.0 s

$Dth_{AL1}$  Element

- 49 First alarm threshold  $\Delta\theta_{AL1}$  ( $Dth_{AL1}$ ) 0.3...1.0  $\Delta\theta_B$

$Dth_{AL2}$  Element

- 49 Second alarm threshold  $\Delta\theta_{AL2}$  ( $Dth_{AL2}$ ) 0.5...1.2  $\Delta\theta_B$

$Dth >$  Element

- 49 Trip threshold  $\Delta\theta$  ( $Dth >$ ) 1.100...1.300  $\Delta\theta_B$

### Phase overcurrent - 50/51

$I >$  Element

- $I >$  Curve type ( $I > Curve$ ) DEFINITE IEC/BS A, B, C, ANSI/IEEE MI, VI, EI RECTIFIER,  $I^2t$  or EM

- $I_{CLP >}$  Activation time ( $t_{CLP >}$ ) 0.00...100.0 s

- $I >$  Reset time delay ( $t_{RES}$ ) 0.00...100.0 s

Definite time

- 50/51 First threshold definite time ( $I >_{def}$ ) 0.100...40.0  $I_n$

- $I >_{def}$  within CLP ( $I_{CLP >_{def}}$ ) 0.100...40.0  $I_n$

- $I >_{def}$  Operating time ( $t >_{def}$ ) 0.04...200 s

Inverse time

- 50/51 First threshold inverse time ( $I >_{inv}$ ) 0.100...40.0  $I_n$

- $I >_{inv}$  within CLP ( $I_{CLP >_{inv}}$ ) 0.100...40.0  $I_n$

- $I >_{inv}$  Operating time ( $t >_{inv}$ ) 0.02...60.0 s

$I > >$  Element

- Type characteristic ( $I > > Curve$ ) DEFINITE,  $I^2t$

- $I_{CLP > >}$  Activation time ( $t_{CLP > >}$ ) 0.00...100.0 s

- $I > >$  Reset time delay ( $t > >_{RES}$ ) 0.00...100.0 s

Definite time

- 50/51 Second threshold definite time ( $I > >_{def}$ ) 0.100...40.0  $I_n$

- $I > >_{def}$  within CLP ( $I_{CLP > >_{def}}$ ) 0.100...40.0  $I_n$

- $I > >_{def}$  Operating time ( $t > >_{def}$ ) 0.03...10.00 s

Inverse time

- 50/51 Second threshold inverse time ( $I > >_{inv}$ ) 0.100...20.00  $I_n$

- $I > >_{inv}$  within CLP ( $I_{CLP > >_{inv}}$ ) 0.100...20.00  $I_n$

- $I > >_{inv}$  Operating time ( $t > >_{inv}$ ) 0.02...10.00 s

$I > > >$  Element

- $I_{CLP > > >}$  Activation time ( $t_{CLP > > >}$ ) 0.00...100.0 s

- $I > > >$  Reset time delay ( $t > > >_{RES}$ ) 0.00...100.0 s

Definite time

- 50/51 Third threshold definite time ( $I > > >_{def}$ ) 0.100...40.0  $I_n$

- $I > > >_{def}$  within CLP ( $I_{CLP > > >_{def}}$ ) 0.100...40.0  $I_n$

- $I > > >_{def}$  Operating time ( $t > > >_{def}$ ) 0.03...10.00 s

### Residual overcurrent - 50N(1)/51N(1)

$I_{E1} >$  Element

- $I_{E1} >$  Curve type ( $I_{E1} > Curve$ ) DEFINITE IEC/BS A, B, C, ANSI/IEEE MI, VI, EI, EM

- $I_{E1CLP >}$  Activation time ( $t_{E1CLP >}$ ) 0.00...100.0 s

- $I_{E1} >$  Reset time delay ( $t_{E1 >_{RES}}$ ) 0.00...100.0 s

Definite time

- 50N(1)/51N(1) First threshold definite time ( $I_{E1} >_{def}$ ) 0.002...10.00  $I_{E1n}$

- $I_{E1} >_{def}$  within CLP ( $I_{E1CLP >_{def}}$ ) 0.002...10.00  $I_{E1n}$

- $I_{E1} >_{def}$  Operating time ( $t_{E1} >_{def}$ ) 0.04...200 s

Inverse time

- 50N(1)/51N(1) First threshold inverse time ( $I_{E1} >_{inv}$ ) 0.002...2.00  $I_{E1n}$

- $I_{E1} >_{inv}$  within CLP ( $I_{E1CLP >_{inv}}$ ) 0.002...2.00  $I_{E1n}$

- $I_{E1} >_{inv}$  Operating time ( $t_{E1} >_{inv}$ ) 0.02...60.0 s

$I_{E1} > >$  Element

- $I_{E1CLP > >}$  Activation time ( $t_{E1CLP > >}$ ) 0.00...100.0 s

- $I_{E1} > >$  Reset time delay ( $t_{E1} > >_{RES}$ ) 0.00...100.0 s

#### Definite time

- 50N(1)/51N(1) Second threshold def. time ( $I_{E1}>>>def$ ) 0.002...10.00  $I_{E1n}$
- $I_{E1}>>>def$  within CLP ( $I_{E1CLP}>>>def$ ) 0.002...10.00  $I_{E1n}$
- $I_{E1}>>>def$  Operating time ( $t_{E1}>>>def$ ) 0.03...10.00 s

#### $I_{E1}>>> Element$

- $I_{E1CLP}>>> Activation$  time ( $t_{E1CLP}>>>$ ) 0.00...100.0 s
- $I_{E1CLP}>>> Reset$  time delay ( $t_{E1}>>>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(1)/51N(1) Third threshold def. time ( $I_{E2}>>>def$ ) 0.002...10.00  $I_{E1n}$
- $I_{E1CLP}>>>def$  within CLP ( $I_{E1CLP}>>>def$ ) 0.002...10.00  $I_{E1n}$
- $I_{E1CLP}>>>def$  Operating time ( $t_{E1}>>>def$ ) 0.03...10.00 s

### — Residual overcurrent - 50N(2)/51N(2)

#### $I_{E2}> Element$

- $I_{E2}> Curve$  type ( $I_{E2}>Curve$ ) DEFINITE  
IEC/BS A, B, C, ANSI/IEEE MI, VI, EI, EM
- $I_{E2CLP}> Activation$  time ( $t_{E2CLP}>$ ) 0.00...100.0 s
- $I_{E2}> Reset$  time delay ( $t_{E2}>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(2)/51N(2) First threshold definite time ( $I_{E2}>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2}>def$  within CLP ( $I_{E2CLP}>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2}>def$  Operating time ( $t_{E2}>def$ ) 0.04...200 s

#### Inverse time

- 50N(2)/51N(2) First threshold inverse time ( $I_{E2}>inv$ ) 0.002...2.00  $I_{E2n}$
- $I_{E2}>inv$  within CLP ( $I_{E2CLP}>inv$ ) 0.002...2.00  $I_{E2n}$
- $I_{E2}>inv$  Operating time ( $t_{E2}>inv$ ) 0.02...60.0 s

#### $I_{E2}>>> Element$

- $I_{E2CLP}>>> Activation$  time ( $t_{E2CLP}>>>$ ) 0.00...100.0 s
- $I_{E2}>>> Reset$  time delay ( $t_{E2}>>>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(2)/51N(2) Second threshold def. time ( $I_{E2}>>>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2}>>>def$  within CLP ( $I_{E2CLP}>>>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2}>>>def$  Operating time ( $t_{E2}>>>def$ ) 0.03...10.00 s

#### $I_{E2}>>> Element$

- $I_{E2CLP}>>> Activation$  time ( $t_{E2CLP}>>>$ ) 0.00...100.0 s
- $I_{E2CLP}>>> Reset$  time delay ( $t_{E2}>>>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(1)/51N(1) Third threshold def. time ( $I_{E2}>>>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2CLP}>>>def$  within CLP ( $I_{E2CLP}>>>def$ ) 0.002...10.00  $I_{E2n}$
- $I_{E2CLP}>>>def$  Operating time ( $t_{E2}>>>def$ ) 0.03...10.00 s

### — Residual overcurrent - 50N(Comp)/51N(Comp)

#### $I_{EC}> Element$ <sup>[1]</sup>

- $I_{EC}> Curve$  type ( $I_{EC}>Curve$ ) DEFINITE  
IEC/BS A, B, C, ANSI/IEEE MI, VI, EI, EM
- $I_{ECCLP}> Activation$  time ( $t_{ECCLP}>$ ) 0.00...100.0 s
- $I_{EC}> Reset$  time delay ( $t_{EC}>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(Comp)/51N(Comp) First threshold def. time ( $I_{E2}>def$ ) 0.100...40.0  $I_n$
- $I_{EC}>def$  within CLP ( $I_{ECCLP}>def$ ) 0.100...40.0  $I_n$
- $I_{EC}>def$  Operating time ( $t_{EC}>def$ ) 0.04...200 s

#### Inverse time

- 50N(Comp)/51N(Comp) First threshold inv. time ( $I_{EC}>inv$ ) 0.100...20.00  $I_n$
- $I_{EC}>inv$  within CLP ( $I_{ECCLP}>inv$ ) 0.100...20.00  $I_n$
- Operating time ( $t_{EC}>inv$ ) 0.02...60.0 s

#### $I_{EC}>>> Element$

- $I_{ECCLP}>>> Activation$  time ( $t_{ECCLP}>>>$ ) 0.00...100.0 s
- $I_{EC}>>> Reset$  time delay ( $t_{EC}>>>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(Comp)/51N(Comp) Second thresh. def. time ( $I_{E2}>>>def$ ) 0.100...40.0  $I_n$
- $I_{E2}>>>def$  within CLP ( $I_{E2CLP}>>>def$ ) 0.100...40.0  $I_n$
- $I_{E2}>>>def$  Operating time ( $t_{E2}>>>def$ ) 0.03...10.00 s

#### $I_{E2}>>> Element$

- $I_{E2CLP}>>> Activation$  time ( $t_{E2CLP}>>>$ ) 0.00...100.0 s
- $I_{E2CLP}>>> Reset$  time delay ( $t_{E2}>>>RES$ ) 0.00...100.0 s

#### Definite time

- 50N(Comp)/51N(Comp) Third thresh. def. time ( $I_{E2}>>>def$ ) 0.100...40.0  $I_n$
- $I_{E2CLP}>>>def$  within CLP ( $I_{E2CLP}>>>def$ ) 0.100...40.0  $I_n$
- $I_{E2CLP}>>>def$  Operating time ( $t_{E2}>>>def$ ) 0.03...10.00 s

Note 1: the computed residual current  $I_{EC}$  is employed (vectorial sum of the phase currents)

### — Overvoltage - 59

#### Common configuration:

- Voltage measurement type for 59 ( $U_{type59}$ ) <sup>[1]</sup>  $U_{ph-ph}/U_{ph-n}$
- 59 Operating logic ( $Logic59$ ) AND/OR

#### $U> Element$

- $U> Curve$  type ( $U>Curve$ ) DEFINITE  
INVERSE <sup>[2]</sup>

#### Definite time

- 59 First threshold definite time ( $U>def$ ) 0.50...1.50  $U_n/E_n$
- $U>def$  Operating time ( $t_U>def$ ) 0.03...100.0 s

#### Inverse time

- 59 First threshold inverse time ( $U>inv$ ) 0.50...1.50  $U_n/E_n$
- $U>inv$  Operating time ( $t_U>inv$ ) 0.10...100.0 s

#### $U>>> Element$

#### Definite time

- 59 Second threshold definite time ( $U>>>def$ ) 0.50...1.50  $U_n/E_n$
- $U>>>def$  Operating time ( $t_U>>>def$ ) 0.03...100.0 s

Note 1: With  $U_{ph-ph}$  setting all threshold are in p.u.  $U_n$   
with  $U_{ph-n}$  setting all threshold are in p.u.  $E_n$

Note 2: The mathematical formula for INVERSE curves is:

$$t = 0.5 \cdot t_{U>inv} / [1 - (U/U_{>inv})]$$

where:

$t$  = operating time (in seconds)

$t_{U>inv}$  = operating time setting (in seconds)

$U$  = input voltage

$U_{>inv}$  = threshold setting

### — Residual overvoltage - 59N <sup>[1]</sup>

#### Common configuration:

- Residual voltage measurement for 59N - computed  $U_{EC}$
- 59N Operating mode from 74VT internal ( $74VTint59N$ ) OFF/Block
- 59N Operating mode from 74VT external ( $74VText59N$ ) OFF/Block

#### $U_E> Element$

- $U_E> Curve$  type ( $U_E>Curve$ ) DEFINITE  
INVERSE <sup>[2]</sup>

- $U_E> Reset$  time delay ( $t_{UE}>RES$ ) 0.00...100.0 s

#### Definite time

- 59N First threshold definite time ( $U_E>def$ ) 0.01...0.70  $U_{En}$
- $U_E>def$  Operating time ( $t_{UE}>def$ ) 0.07...100.0 s

#### Inverse time

- 59N First threshold inverse time ( $U_E>inv$ ) 0.01...0.50  $U_{En}$
- $U_E>inv$  Operating time ( $t_{UE}>inv$ ) 0.10...100.0 s

#### $U_E>>> Element$

- $U_E>>> Reset$  time delay ( $t_{UE}>>>RES$ ) 0.00...100.0 s
- 59N Second threshold definite time ( $U_E>>>def$ ) 0.01...0.70  $U_{En}$
- $U_E>>>def$  Operating time ( $t_{UE}>>>def$ ) 0.07...100.0 s

Note 1: The computed residual voltage  $U_{EC}$  is employed (vectorial sum of the phase voltages)

Note 2: The mathematical formula for INVERSE curves is:

$$t = 0.5 \cdot t_{UE>inv} / [(U_{EC}/U_{E>inv}) - 1]$$

where:

$t$  = operating time (in seconds)

$t_{UE>inv}$  = operating time setting (in seconds)

$U_{EC}$  = computed residual voltage

$U_{E>inv}$  = threshold setting

### — Directional phase overcurrent - 67

#### Common configuration:

- 67 Operating mode ( $Mode67$ )  $I/I \cdot \cos$
- 67 Operating logic ( $Logic67$ ) 1/3 / 2/3
- 67 Operating mode from 74VT internal ( $74VTint67$ ) OFF/Block/Not directional
- 67 Operating mode from 74VT external ( $74VText67$ ) OFF/Block/Not directional

#### $I_{PD}> Element$

- $I_{PD}> Curve$  type ( $I_{PD}>Curve$ ) DEFINITE  
IEC/BS A, B, C

ANSI/IEEE MI, VI, EI  
RECTIFIER, I<sup>2</sup>t or EM

- $I_{PDCLP}> Activation$  time ( $t_{PDCLP}>$ ) 0.00...100.0 s
- $I_{PD}> Reset$  time delay ( $t_{PD}>RES$ ) 0.00...100.0 s

#### Definite time

- 67 First threshold definite time ( $I_{PD>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>def}$  characteristic angle ( $\Theta_{\theta PD>def}$ ) 0...359°
- $I_{PD>def}$  within CLP ( $I_{PDCLP>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>def}$  Operating time ( $t_{PD>def}$ ) 0.05...200 s

#### Inverse time

- 67 First threshold inverse time ( $I_{PD>inv}$ ) 0.100...10.0  $I_n$
- $I_{PD>inv}$  characteristic angle ( $\Theta_{\theta PD>inv}$ ) 0...359°
- $I_{PD>inv}$  within CLP ( $I_{PDCLP>inv}$ ) 0.100...10.0  $I_n$
- $I_{PD>inv}$  Operating time ( $t_{PD>inv}$ ) 0.02...60.0 s

#### $I_{PD>>}$ Element

- $I_{PD>>}$  Curve type ( $I_{PD>>Curve}$ ) DEFINITE  
IEC/BS A, B, C, ANSI/IEEE MI, VI, EI  
RECTIFIER, I<sup>2</sup>t or EM
- $I_{PDCLP>>}$  Activation time ( $t_{PDCLP>>}$ ) 0.00...100.0 s
- $I_{PD>>}$  Reset time delay ( $t_{PD>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67 Second threshold definite time ( $I_{PD>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>def}$  characteristic angle ( $\Theta_{\theta PD>>def}$ ) 0...359°
- $I_{PD>>def}$  within CLP ( $I_{PDCLP>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>def}$  Operating time ( $t_{PD>>def}$ ) 0.04...200 s

#### Inverse time

- 67 Second threshold inverse time ( $I_{PD>>inv}$ ) 0.100...10.0  $I_n$
- $I_{PD>>inv}$  characteristic angle ( $\Theta_{\theta PD>>inv}$ ) 0...359°
- $I_{PD>>inv}$  within CLP ( $I_{PDCLP>>inv}$ ) 0.100...10.0  $I_n$
- $I_{PD>>inv}$  Operating time ( $t_{PD>>inv}$ ) 0.02...60.0 s

#### $I_{PD>>>}$ Element

- $I_{PDCLP>>>}$  Activation time ( $t_{PDCLP>>>}$ ) 0.00...100.0 s
- $I_{PD>>>}$  Reset time delay ( $t_{PD>>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67 Third threshold definite time ( $I_{PD>>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>>def}$  characteristic angle ( $\Theta_{\theta PD>>>def}$ ) 0...359°
- $I_{PD>>>def}$  within CLP ( $I_{PDCLP>>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>>def}$  Operating time ( $t_{PD>>>def}$ ) 0.04...10.00 s

#### $I_{PD>>>>}$ Element

- $I_{PDCLP>>>>}$  Activation time ( $t_{PDCLP>>>>}$ ) 0.00...100.0 s
- $I_{PD>>>>}$  Reset time delay ( $t_{PD>>>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67 Fourth threshold definite time ( $I_{PD>>>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>>>def}$  characteristic angle ( $\Theta_{\theta PD>>>>def}$ ) 0...359°
- $I_{PD>>>>def}$  within CLP ( $I_{PDCLP>>>>def}$ ) 0.100...40.0  $I_n$
- $I_{PD>>>>def}$  Operating time ( $t_{PD>>>>def}$ ) 0.04...10.00 s

### — Directional earth fault overcurrent - 67N<sup>[1]</sup>

#### Common configuration:

- 67N Operating mode ( $Mode67N$ )  $I/I \cdot \cos$
- Residual voltage measurement type for 67N - direct/calculated ( $3VoType67N$ )  $U_{EC}$
- 67N Multiplier of threshold for insensitive zone ( $M$ ) 1.5...10.0
- 67N Operating mode from 74VT internal ( $74VTint67N$ )  
OFF/Block/Not directional
- 67N Operating mode from 74VT external ( $74VText67N$ )  
OFF/Block/Not directional

#### $I_{ED>}$ Element

- $I_{ED>}$  Curve type DEFINITE  
IEC/BS A, B, C, ANSI/IEEE MI, VI, EI, EM
- $I_{EDCLP>}$  Activation time ( $t_{EDCLP>}$ ) 0.00...100.0 s
- $I_{ED>}$  Reset time delay ( $t_{ED>RES}$ ) 0.00...100.0 s

#### Definite time

- 67N First threshold definite time ( $I_{ED>def} - U_{ED>def}$ )
- Residual current pickup value 0.002...10.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>def}$  within CLP ( $I_{EDCLP>def}$ ) 0.002...10.00  $I_{E1n}$
- $I_{ED>def}$  Operating time ( $t_{ED>def}$ ) 0.05...200 s

#### Inverse time

- 67N First threshold inverse time ( $I_{ED>inv} - U_{ED>inv}$ )
- Residual current pickup value 0.002...2.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>inv}$  within CLP ( $I_{EDCLP>inv}$ ) 0.002...2.00  $I_{E1n}$
- $I_{ED>inv}$  Operating time ( $t_{ED>inv}$ ) 0.02...60.0 s

#### $I_{ED>>}$ Element

- $I_{ED>>}$  Curve type ( $I_{ED>>Curve}$ ) DEFINITE  
IEC/BS A, B, C, ANSI/IEEE MI, VI, EI, EM
- $I_{EDCLP>>}$  Activation time ( $t_{EDCLP>>}$ ) 0.00...100.0 s
- $I_{ED>>}$  Reset time delay ( $t_{ED>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67N Second threshold definite time ( $I_{ED>>def} - U_{ED>>def}$ )
- Residual current pickup value 0.002...10.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>>def}$  within CLP ( $I_{EDCLP>>def}$ ) 0.002...10.00  $I_{E1n}$
- $I_{ED>>def}$  Operating time ( $t_{ED>>def}$ ) 0.05...10.00 s

#### Inverse time

- 67N Second threshold inverse time ( $I_{ED>>inv} - U_{ED>>inv}$ )
- Residual current pickup value 0.002...2.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>>inv}$  within CLP ( $I_{EDCLP>>inv}$ ) 0.002...2.00  $I_{E1n}$
- $I_{ED>>inv}$  Operating time ( $t_{ED>>inv}$ ) 0.02...60.0 s

#### $I_{ED>>>}$ Element

- $I_{EDCLP>>>}$  Activation time ( $t_{EDCLP>>>}$ ) 0.00...100.0 s
- $I_{ED>>>}$  Reset time delay ( $t_{ED>>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67N Third threshold definite time ( $I_{ED>>>def} - U_{ED>>>def}$ )
- Residual current pickup value 0.002...10.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>>>def}$  within CLP ( $I_{EDCLP>>>def}$ ) 0.002...10.00  $I_{E1n}$
- $I_{ED>>>def}$  Operating time ( $t_{ED>>>def}$ ) 0.05...10.00 s

#### $I_{ED>>>>}$ Element

- $I_{EDCLP>>>>}$  Activation time ( $t_{EDCLP>>>>}$ ) 0.00...100.0 s
- $I_{ED>>>>}$  Reset time delay ( $t_{ED>>>>RES}$ ) 0.00...100.0 s

#### Definite time

- 67N Fourth threshold definite time ( $I_{ED>>>>def} - U_{ED>>>>def}$ )
- Residual current pickup value 0.002...10.00  $I_{E1n}$
- Residual voltage pickup value 0.004...0.500  $U_{ECn}$
- Characteristic angle 0...359°
- Half operating sector 1...180°
- $I_{ED>>>>def}$  within CLP ( $I_{EDCLP>>>>def}$ ) 0.002...10.00  $I_{E1n}$
- $I_{ED>>>>def}$  Operating time ( $t_{ED>>>>def}$ ) 0.05...10.00 s

Note 1: the computed residual voltage  $U_{EC}$  (vectorial sum of the phase voltages) and measured residual current  $I_{E1}$  are employed

### — Selective block - BLOCK2

#### Selective block IN:

- BLIN Max activation time for phase protections ( $t_{B-IPh}$ ) 0.10...10.00 s
- BLIN Max activation time for ground protections ( $t_{B-IE}$ ) 0.10...10.00 s

#### Selective block OUT:

- BLOUT Dropout time delay for phase protections ( $t_{F-IPh}$ ) 0.00...1.00 s
- BLOUT Drop-out time delay for ground protections ( $t_{F-IE}$ ) 0.00...1.00 s
- BLOUT Drop-out time delay for phase and ground protections ( $t_{F-IPh/IE}$ ) 0.00...1.00 s

### — Internal selective block - BLOCK4

- Output internal selective block dropout time for phase protections ( $t_{F-IPh}$ ) 0.00...10.00 s
- Output internal selective block dropout time for ground protections ( $t_{F-IE}$ ) 0.00...10.00 s

### — Breaker failure - BF

- BF Phase current threshold ( $I_{BF>}$ ) 0.05...1.00  $I_n$
- BF Residual current threshold from  $I_{E1}$  input ( $I_{E1BF>}$ ) 0.01...2.00  $I_{E1n}$
- BF Residual current threshold from  $I_{E2}$  input ( $I_{E2BF>}$ ) 0.01...2.00  $I_{E2n}$
- BF Time delay ( $t_{BF}$ ) 0.06...10.00 s

## — Second Harmonic Restraint - 2ndh-REST

Second harmonic restraint threshold ( $I_{2ndh}>$ )	10...50 %
$I_{2ndh}>$ Reset time delay ( $t_{2ndh>RES}$ )	0.00...100.0 s

## — VT supervision - 74VT

74VT Negative sequence overvoltage threshold ( $U_{2VT>}$ )	0.05...0.50 $E_n$
74VT Negative sequence overvoltage threshold ( $I_{2VT>}$ )	0.05...0.50 $I_n$
74VT Phase undervoltage threshold ( $U_{VT<}$ )	0.05...0.50 $E_n$
74VT Minimum change of current threshold 74VT ( $D_{VT<}$ )	0.05...0.50 $I_n$
74VT Undercurrent inhibition threshold ( $I_{VT<}$ )	0.100...40.0 $I_n$
74VT Alarm time delay ( $t_{VT-AL}$ )	0.0...10.0 s

## — CT supervision - 74CT

74CT Threshold ( $S<$ )	0.10...0.95
74CT Overcurrent threshold ( $I^*$ )	0.10...1.00 $I_n$
$S<$ Operating time ( $t_{S<}$ )	0.03...200 s

## — Circuit Breaker supervision

Number of CB trips ( $N_{Open}$ )	0...10000
Cumulative CB tripping currents ( $SumI$ )	0...5000 $I_n$
CB opening time for $I^2t$ calculation ( $t_{break}$ )	0.05...1.00 s
Cumulative CB tripping $I^2t$ ( $SumI^2t$ )	0...5000 $I_n^2 \cdot s$
CB max allowed opening time ( $t_{break>}$ )	0.05...1.00 s

## — Pilot wire diagnostic

BLOUT1 Diagnostic pulses period ( $PulseBLOUT1$ )	OFF - 0.1-1-5-10-60-120 s
BLIN1 Diagnostic pulses control time interval ( $PulseBLIN1$ )	OFF - 0.1-1-5-10-60-120 s

## METERING & RECORDING

### — Measured parameters

#### Direct:

• Frequency	$f$
• Fundamental RMS phase currents	$I_{L1}, I_{L2}, I_{L3}$
• Fundamental RMS phase voltages	$U_{L1}, U_{L2}, U_{L3}$
• Fundamental RMS residual currents	$I_{E1}, I_{E2}$

#### Calculated:

• Thermal image	$DTheta$
• Fundamental RMS phase-to-phase voltages	$U_{12}, U_{23}, U_{31}$
• Fundamental RMS calculated residual voltage	$U_{EC}$
• Fundamental RMS calculated residual current	$I_{EC}$
• Maximum current between $I_{L1}-I_{L2}-I_{L3}$	$I_{Lmax}$
• Minimum current between $I_{L1}-I_{L2}-I_{L3}$	$I_{Lmin}$
• Average current between $I_{L1}-I_{L2}-I_{L3}$	$I_L$
• Maximum voltage between $U_{L1}-U_{L2}-U_{L3}$	$U_{Lmax}$
• Average voltage between $U_{L1}-U_{L2}-U_{L3}$	$U_L$
• Maximum voltage between $U_{12}-U_{23}-U_{31}$	$U_{max}$
• Average voltage between $U_{12}-U_{23}-U_{31}$	$U$

#### Phase:

• Displacement angle of $I_{L1}$ respect to $U_{L1}$	$PhiL1$
• Displacement angle of $I_{L2}$ respect to $U_{L2}$	$PhiL2$
• Displacement angle of $I_{L3}$ respect to $U_{L3}$	$PhiL3$
• Displacement angle of $I_{L1}$ respect to $U_{23}$	$Alpha1$
• Displacement angle of $I_{L2}$ respect to $U_{31}$	$Alpha2$
• Displacement angle of $I_{L3}$ respect to $U_{12}$	$Alpha3$
• Displacement angle of $U_{EC}$ respect to $I_{E1}$	$PhiEC$

#### Sequence:

• Positive sequence current	$I_1$
• Negative sequence current	$I_2$
• Negative sequence current/positive sequence current ratio	$I_2/I_1$
• Negative sequence voltage	$U_2$

#### Power:

• Total active power	$P$
• Total reactive power	$Q$
• Total apparent power	$S$
• Power factor	$cosPhi$
• Phase active powers	$P_{L1}, P_{L2}, P_{L3}$
• Phase reactive powers	$Q_{L1}, Q_{L2}, Q_{L3}$
• Power factors	$cosPhiL1, cosPhiL2, cosPhiL3$

#### 2nd harmonic:

• Second harmonic phase currents	$I_{L1-2nd}, I_{L2-2nd}, I_{L3-2nd}$
• Maximum of the second harmonic phase currents/fundamental component percentage ratio	$I_{-2nd} / I_L$

#### 3rd harmonic:

• Third harmonic phase currents	$I_{L1-3rd}, I_{L2-3rd}, I_{L3-3rd}$
• Third harmonic $I_{E1}$ residual current	$I_{E1-3rd}$

#### 4th harmonic:

• Fourth harmonic phase currents	$I_{L1-4th}, I_{L2-4th}, I_{L3-4th}$
----------------------------------	--------------------------------------

#### 5th harmonic:

• Fifth harmonic phase currents	$I_{L1-5th}, I_{L2-5th}, I_{L3-5th}$
---------------------------------	--------------------------------------

#### Demand phase currents:

• Phase fixed currents demand	$I_{L1FIX}, I_{L2FIX}, I_{L3FIX}$
• Phase rolling currents demand	$I_{L1ROL}, I_{L2ROL}, I_{L3ROL}$
• Phase peak currents demand	$I_{L1MAX}, I_{L2MAX}, I_{L3MAX}$
• Phase minimum currents demand	$I_{L1MIN}, I_{L2MIN}, I_{L3MIN}$

#### Demand power:

• Fixed active power demand	$P_{FIX}$
• Fixed reactive power demand	$Q_{FIX}$
• Rolling active power demand	$P_{ROL}$
• Rolling reactive power demand	$Q_{ROL}$
• Peak active power demand	$P_{MAX}$
• Peak reactive power demand	$Q_{MAX}$
• Minimum active power demand	$P_{MIN}$
• Minimum reactive power demand	$Q_{MIN}$

#### Energy:

• Positive active energy	$E_{A+}$
• Negative active energy	$E_{A-}$
• Total active energy	$E_A$
• Positive reactive energy	$E_{Q+}$
• Negative reactive energy	$E_{Q-}$
• Total reactive energy	$E_Q$

#### PT100:

• Temperature PT1...PT8	$T_1... T_8$
-------------------------	--------------

### — Event recording (SER)

Number of events	300
Recording mode	circular

#### Trigger:

• Start and trip of any enabled protection or control function	
• Binary inputs switching (off/on and on/off)	
• Power ON and power OFF (auxiliary power supply)	
• Setting changes	

#### Data recorded:

• Event counter (resettable by ThySetter)	0...10 <sup>9</sup>
• Event cause	binary input/output relay/setting changes
• Time stamp	Date and time

### — Fault recording (SFR)

Number of faults	20
Recording mode	circular

#### Trigger:

• External trigger	binary input set as Fault trigger
• Element and control pickup	output relays OFF-ON transition

#### Data recorded:

• Time stamp	Date and time
• Fault cause	start, trip, binary input
• Fault counter (resettable by ThySetter)	0...10 <sup>9</sup>
• Fundamental RMS phase currents	$I_{L1r}, I_{L2r}, I_{L3r}$
• Fundamental RMS residual currents	$I_{E1r}, I_{E2r}, I_{ECr}$
• Fundamental RMS phase voltages	$U_{L1r}, U_{L2r}, U_{L3r}$
• Fundamental RMS phase-to-phase voltages	$U_{12r}, U_{23r}, U_{31r}$
• Fundamental RMS residual voltages (calculated)	$U_{ECr}$
• Displacement angles ( $I_{L1}-U_{L1}, I_{L2}-U_{L2}, I_{L3}-U_{L3}$ )	$PhiL1r, PhiL2r, PhiL3r$
• Displacement angles ( $I_{L1}-U_{23}, I_{L2}-U_{31}, I_{L3}-U_{12}$ )	$Alpha1r, Alpha2r, Alpha3r$
• Displacement angle ( $U_{EC}-I_{E12}$ )	$PhiECr$
• Thermal image	$DTheta-r$
• Binary inputs state	IN1, IN2...INx
• Output relays state	K1...K6...Kx
• Fault cause info (operating phase)	L1, L2, L3



## Digital Fault Recorder (Oscillography)

File format	COMTRADE
Records	depending on setting <sup>[1]</sup>
Recording mode	circular
Sampling rate	24 samples per cycle

### Trigger setup:

• Pre-trigger time	0.05...1.00 s
• Post-trigger time	0.05...60.00 s
• Trigger from inputs	IN1, INx
• Trigger from outputs	K1...Kx
• Manual command	ThySetter

### Set sample channels:

• Instantaneous currents	$i_{L1}, i_{L2}, i_{L3}, i_{E1}, i_{E2}$
• Instantaneous voltages	$u_{L1}, u_{L2}, u_{L3}$

### Set analog channels (Analog 1...12):

• Frequency	$f$
• Fundamental RMS phase currents	$I_{L1}, I_{L2}, I_{L3}$
• Fundamental RMS residual current	$I_{E1}, I_{E2}$
• Fundamental RMS phase voltages	$U_{L1}, U_{L2}, U_{L3}$
• Fundamental RMS calculated residual current	$I_{EC}$
• Fundamental RMS computed residual voltage	$U_{EC}$
• Fundamental RMS phase-to-phase voltages	$U_{12}, U_{23}, U_{31}$
• Displacement angles ( $i_{L1}-U_{L1}, i_{L2}-U_{L2}, i_{L3}-U_{L3}$ )	$\Phi_{iL1}, \Phi_{iL2}, \Phi_{iL3}$
• Displacement angles ( $i_{L1}-U_{23}, i_{L2}-U_{31}, i_{L3}-U_{12}$ )	$\alpha_{1}, \alpha_{2}, \alpha_{3}$
• Displacement angle ( $U_{EC}-I_{E1}$ )	$\Phi_{iEC}$
• Second harmonic phase currents	$I_{L1-2nd}, I_{L2-2nd}, I_{L3-2nd}$
• Maximum of the second harmonic phase currents/fundamental component percentage ratio	$I_{-2nd}/I_L$
• Temperature	$T1...T8$


### Set digital channels (Digital 1...12):

• Output relays state	K1...Kx
• Binary inputs state	IN1, INx


Note 1 - For instance, with following setting:

• Pre-trigger time	0.25 s
• Post-trigger time	0.25 s
• Sampled channels	$i_{L1}, i_{L2}, i_{L3}, i_{E1}, i_{E2}, u_{L1}, u_{L2}, u_{L3}$
• Analog channels	$I_{L1}, I_{L2}, I_{L3}, I_{E1}, I_{E2}, U_{L1}, U_{L2}, U_{L3}, U_{EC}$
• Digital channels	K1, K2, K3, K4, K5, K6, IN1, IN2

More than 270 records can be stored with  $f = 50$  Hz



— Connection diagram example



(\*) OPERATION FOR:


- 67 elements with characteristic angle adjusted within  $0^\circ \dots 90^\circ$  or  $270^\circ \dots 359^\circ$  ranges
- 67N elements for insulated neutral systems and characteristic angle setting =  $90^\circ$

(\*\*) MEASUREMENTS:


- Positive sign for measurement of active power and energy with passive load
- Negative sign for measurement of active power and energy with generators

# DIMENSIONS

## FRONT VIEW




FLUSH MOUNTING




PROJECTING MOUNTING

## REAR VIEW




FLUSH MOUNTING




PROJECTING MOUNTING  
(Separate operator panel)


## SIDE VIEW




FLUSH MOUNTING



SEPARATE  
OPERATOR PANEL




PROJECTING MOUNTING  
(Separate operator panel)




PROJECTING MOUNTING  
(Stand alone)

## RACK MOUNTING



## FLUSH MOUNTING CUTOUT



**[www.thytronic.it](http://www.thytronic.it)**



A PERSONALISED SERVICE OF THE PRODUCTION, A RAPID DELIVERY, A COMPETITIVE PRICE AND AN ATTENTIVE EVALUATION OF OUR CUSTOMERS NEEDS, HAVE ALL CONTRIBUTED IN MAKING US ONE OF THE BEST AND MOST RELIABLE PRODUCERS OF PROTECTIVE RELAYS. FORTY YEARS OF EXPERIENCE HAS MADE STANDARD THESE ADVANTAGES THAT ARE GREATLY APPRECIATED BY LARGE COMPANIES THAT DEAL ON THE INTERNATIONAL MARKET. A HIGHLY QUALIFIED AND MOTIVATED STAFF PERMITS US TO OFFER AN AVANT-GARDE PRODUCT AND SERVICE WHICH MEET ALL SAFETY AND CONTINUITY DEMANDS, VITAL IN THE GENERATION OF ELECTRIC POWER. OUR COMPANY PHILOSOPHY HAS HAD A POSITIVE REACTION FROM THE MARKET BY BACKING OUR COMMITMENT AND HENCE STIMULATING OUR GROWTH.